



Test Verification of Conformity

On the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the essential requirements of the referenced specifications at the time the tests were carried out.

Applicant Name & Address : Remote Technologies
5775 12th Avenue East, Suite 180
Shakopee, MN 55379

Product(s) Tested : In-Wall Controller

Model(s) : RK3-V

Brand name : RTI

Relevant Standard(s)/Specification(s) : EN 55022:2006, Class B
47 CFR, Part 15:2007, §15.107 and §15.109, Class B
EN 55024:1998 + A1:2001 + A2:2003

Verification Issuing Office Name & Address : Intertek, Oakdale, Minnesota
EMC Department

Date of Test(s) : September 22 – 26, 2008

Verification/Report Number(s) : 3162238MIN-001

NOTE : This verification is part of the full test report(s) and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Signature: 

Name:	Simon Khazon
Position:	Sr. EMC Project Engineer
Date:	September 29, 2008